

Conditions Imposed for the purpose of Sulphur Burning

The burning of sulphur is a process which has been identified by CFS as an activity which requires a permit to be issued pursuant to the Fire and Emergency Services Act 2005.

A site inspection will be conducted by the Fire Prevention Officer prior to a permit being issued.

- 1. In all cases where mains water and appropriate hoses are not available, a minimum of 400 litres of water shall be provided on site and easily accessible in the event of an emergency.
- 2. A filled knapsack (in good working order) or other fire extinguisher capable of controlling the fire must be readily accessible on site at all times.
- 3. Ensure an effective fire break is maintained at all times. A clearing of all flammable material around the structure is to be maintained to a minimum distance of 4 metres at all times.
- 4. The District Council of Loxton Waikerie has the power to revoke a permit during the fire danger season, if on inspection of the site, the permit holder is found to be negligent in not complying with the conditions of the permit.
- 5. Periodic site inspections shall be carried out by an authorised officer to ensure compliance of permit conditions are met and maintained.

These conditions are in addition to the conditions on the back of the Schedule 9 and 10 permits issued